

**McGowan Lake Campground Inc.**

**Holding Tank Specifications – Schedule B**

**Installing and setting up a new drum:**

1. Must be no more than 45 gallons
2. Completely sealed plastic drum
3. Trailer to drain into drum through 3" ABS completely exposed piping sealed with glue and/or calking to drum exterior \*\*Flex hose is only to be used where ABS cannot and must be approved by management\*\*
4. Outlet to be fitted with 3" ABS cleanout, sealed with glue and/or calking to drum exterior
5. Drum must be fitted with a separate intake and outtake cleanout
6. Top of drum to be exposed 2" above ground to allow viewing access to top of drum exterior

**\*\*Please see management for best possible location of drum for accessibility of honey wagon and to avoid water and hydro line damage. Remember CALL BEFORE YOU DIG\*\***

**Regular Maintenance and Upkeep:**

1. All septic areas must be clean, easily accessible and free of debris including leaves, grass, weeds, rocks and dirt buildup
2. Before pulling your valves, make sure that your glue and/or calking has not come away from the intake/outtake seals on the drum
3. When pulling your valves, check at all connections to make sure there is nothing leaking
4. Make sure that the cap is easily removable for clean outs

**Pumpouts will not be done if:**

1. The area around the septic is not maintained
2. There are any leaks
3. Management has asked you to repair an issue and it has not been resolved

**\*\*ALL grey water and black water MUST go into the septic drum\*\***